

Kurzanleitung

MA55

Messanzeige



Ausführlichere Dokumentationen unter
<http://www.siko-global.com/p/ma55>

Allgemeine Hinweise

Vor der Installation, einschließlich in Gefahrenbereichen, lesen Sie die Montageanleitung (Download Internet). Sie enthält die Sicherheitsvorschriften, Hinweise und technischen Daten, die bei der Installation zu beachten sind. Änderungen sind vorbehalten.

⚠ Vorsicht

Damit dieses Produkt zuverlässig funktioniert, muss es sachgemäß transportiert, aufbewahrt, positioniert und montiert werden. Es muss mit Sorgfalt betrieben und gewartet werden. Nur entsprechend qualifiziertes Personal darf dieses Produkt installieren und betreiben.

Sicherheitshinweise

Aus Sicherheitsgründen ist es wichtig, dass Sie die folgenden Punkte lesen und verstehen, bevor Sie das System installieren:

- Installation, Anschluss, Inbetriebnahme und Wartung ist von Personal auszuführen, das entsprechend qualifiziert ist.
- Es liegt in der Verantwortung des Kunden, dass das betreffende Personal vor der Installation des Gerätes die Anweisungen und Richtungsangaben in dieser Anleitung und in der Montageanleitung versteht und befolgt.
- Es liegt in der Verantwortung des Kunden, sicherzustellen, dass der Messanzeige richtig angeschlossen und konfiguriert ist.
- Reparatur und Wartung ist nur von Personal durchzuführen, das von SIKO besonders geschult wurde.




SIKO GmbH
Weiherrmattenweg 2
79256 Buchenbach
www.siko-global.com

Telefon: +49 7661 394-0
Telefax: +49 7661 394-388
Service: support@siko-global.com

Montage Messanzeige

Für den Schalttafeleinbau gelten empfohlene Abmessungen entsprechend IEC 61554.

- In der Schalttafel ① muss der Ausschnitt für die Anzeige vorgesehen sein.
- Die Anzeige wird in den Schalttafel Ausschnitt geschoben, bis die seitlichen Befestigungslaschen einschnappen.
- Durch Klemmung der Befestigungslaschen wird die Anzeige gehalten, kann aber auch leicht demontiert werden.




Elektrische Installation

Der Einsatzort ist so zu wählen, dass induktive oder kapazitive Störungen nicht auf die Messanzeige oder dessen Anschlussleitung einwirken können!

- Das System in möglichst großem Abstand von Leitungen einbauen, die mit Störungen belastet sind. Schirmbleche oder metallisierte Gehäuse verwenden.
- Schützpulen müssen mit Funkenlöschgliedern beschaltet sein.

Anschlussbelegung



PIN	Belegung
1	+UB (Geberversorgung)
2	A-Signal
3	B-Signal
4	Indesignal (I/O)
5	GND (Schirm Geberversorgung)
6	RFS (Signal von Referenzpunktgeber)
7	GND (für Referenzpunktgeber)
8	PE
9	0 V
10	+24 V DC ±20 %


Technische Daten

Elektrische Daten	Ergänzung	
Betriebsspannung	24 V DC ±20 %	
Stromaufnahme	~60 mA	bei 24 V DC, ohne Geber

Quick Start Guide

MA55

Electronic display



For detailed documentation please refer under <http://www.siko-global.com/p/ma55>

General information

Prior to installation, including in hazard areas, read the Installation Instruction (download from the internet). It contains the safety instructions, hints and technical data to be observed during installation. Subject to change without notice.

⚠ Caution

In order to ensure reliable functioning of this product, take care to transport, store, position and mount it appropriately. Exercise care when you operate and maintain the device. Only properly qualified personnel is authorized to install and operate this product.

Safety information

It is important for safety reasons that you read and understand the below instructions before you install the system:

- Installation, connection, commissioning and maintenance shall be done by properly qualified personnel.
- It is the responsibility of the customer to ensure that the personnel concerned read and follow the instructions and directions of this Guide and of the Installation Instruction.
- It is the responsibility of the customer to ensure that the electronic display is correctly connected and configured.
- Only personnel specifically trained by SIKO shall execute repair and maintenance work.




SIKO GmbH
Weiherrmattenweg 2
79256 Buchenbach
www.siko-global.com

Phone: +49 7661 394-0
Fax: +49 7661 394-388
Service: support@siko-global.com

Mounting of the electronic display

For switchboard installation the recommended dimensions of IEC 61554 shall be applied.

- Panel ① must be provided with cutout for MA55.
- Push the display into the panel cutout until the mounting tabs snap completely.
- Mounting tabs hold the unit, but allow easy removal, too.




Electrical Installation

The location should be selected to ensure that no capacitive or inductive interferences can affect the electronic display or the connection lines!

- When mounting the system keep a maximum possible distance from lines loaded with interference. Use screening shields or metallized housings.
- Contactor coils must be linked with spark suppression.

Connection



PIN	Designation
1	+UB (encoder supply)
2	signal A
3	signal B
4	index signal (I/O)
5	GND (screen encoder supply)
6	RFS (signal for reference point source)
7	GND (for reference point source)
8	PE
9	0 V
10	+24 V DC ±20 %

Technical data

Electrical data	Additional information	
Operating voltage	24 V DC ±20 %	
Current consumption	~60 mA	at 24 V DC, without encoder